



107	1 EA	VWT12B	SPREADER
108	0 MBTU	1.25	MANIFOLD
8	1 EA	V4B36B	RANGE
109	140 MBTU	1.25	32 AFF
9	1 EA	VCBB36C	CHAR BROILER
110	131 MBTU	1.25	MANIFOLD

GAS CONNECTION #1:
LOCATED IN ITEM# 1
PIPE SIZE: 1.25 NPT
OP HEIGHT: 32" AFF
TOTAL GAS LOAD: 271 MBTU
FEEDS: 9 8 7
NOTE:

GENERAL NOTES - PLEASE READ

VENTILATION:
ALL COOKING EQUIPMENT MUST BE VENTILATED BY AN APPROVED APPLIANCE IN ACCORDANCE WITH ALL APPLICABLE CODES.

FIRE SUPPRESSION:
ALL COOKING EQUIPMENT MUST BE PROTECTED BY AN APPROVED FIRE SUPPRESSION SYSTEM IN ACCORDANCE WITH ALL APPLICABLE CODES.

CONNECTIONS:
ALL PIPING, FITTINGS, AND INTERCONNECTION SERVICES SHOWN ARE TO BE SUPPLIED AND INSTALLED BY LICENSED CONTRACTORS IN ACCORDANCE WITH ALL LOCAL CODES.

GAS CONNECTIONS:
EXTERNAL GAS REGULATORS, FLEXIBLE GAS LINES AND RESTRAINING CABLES PROVIDED WITH THE EQUIPMENT MUST BE INSTALLED BY LICENSED CONTRACTORS IN ACCORDANCE WITH ALL LOCAL CODES. INCOMING GAS MANIFOLD SUPPLY PRESSURE MUST NOT EXCEED 0.5 PSI (4" W.C.)

BY OTHERS:
VERIFY ALL EQUIPMENT LISTED AS BY OTHERS FOR SIZE AND MECHANICAL SERVICE REQUIREMENTS.

NOTE:
IN LINE WITH THE POLICY TO CONTINUALLY IMPROVE ITS PRODUCTS, THE MANUFACTURER RESERVE THE RIGHT TO CHANGE MATERIALS AND SPECIFICATIONS WITHOUT NOTICE.

●	CONNECTION POINT
○	COLD WATER
△	HOT WATER
⊕	HOT + COLD WATER
○	DRAIN
⚡	POWER
⚡	SWITCH
⚡	CORD SET
⚡	CONV. OUTLET RECP
⚡	DUPLEX RECP
⚡	SINGLE RECP
⚡	GAS
⚡	STEAM SUPPLY
⚡	STEAM RETURN
⚡	STEAM TAKE OFF
⚡	EXHAUST VENT
⚡	SUPPLY VENT
⚡	REFRIGERATION

06-03-2022

PROJECT CODE
AUTH3

AUTOGRAPH HOTEL - 3

AUSTIN

REVISIONS

By ddb
Date 06-03-2022
No. 02
Revision
LARGE FORMAT

NEXT STEP DESIGN

913 WEST ST.

ANNAPOLIS, MD 21401

SCALE:
AS NOTED

DATE: 06-03-2022

DRAWN BY: DDB

VH-AUTH3

1

OF 1

VULCAN

THE VULCAN HART COMPANY
BALTIMORE, MARYLAND
410-284-0660