



GAS CONNECTION #1
LOCATED IN ITEM: 228
PIPE SIZE: 1.25 NPT
CP HEIGHT: 32" AFF
TOTAL GAS LOAD: 242 MBTU
FEEDS: 228
NOTE:

GAS CONNECTION #2
LOCATED IN ITEM: 225
PIPE SIZE: 1.25 NPT
CP HEIGHT: 32" AFF
TOTAL GAS LOAD: 192 MBTU
FEEDS: 227 225
NOTE:

GAS CONNECTION #3
LOCATED IN ITEM: 255
PIPE SIZE: 1.25 NPT
CP HEIGHT: 32" AFF
TOTAL GAS LOAD: 271 MBTU
FEEDS: 252 255
NOTE:

225	1 EA	VGMT36C	RANGE
①	140 MBTU	1.25	32 AFF
②	120 (1)	4.9A	5-15
226	1 EA	36IRB	SALAMANDER WALL MOUNT
①	30 MBTU	0.75	78
227	1 EA	V2B12B	RANGE
①	70 MBTU	1.25	MANIFOLD
228	1 EA	V6B36C	RANGE
①	242 MBTU	1.25	32 AFF
②	120 (1)	4.0A	5-15
229	1 EA	VWT12B	SPREADER
252	1 EA	VCBB36C	CHAR BROILER
①	131 MBTU	1.25	MANIFOLD
255	1 EA	V4B36B	RANGE
①	140 MBTU	1.25	32 AFF
256	1 EA	VWT12B	SPREADER

GENERAL NOTES - PLEASE READ

VENTILATION:
ALL COOKING EQUIPMENT MUST BE VENTILATED BY AN APPROVED APPLIANCE IN ACCORDANCE WITH ALL APPLICABLE CODES.

FIRE SUPPRESSION:
ALL COOKING EQUIPMENT MUST BE PROTECTED BY AN APPROVED FIRE SUPPRESSION SYSTEM IN ACCORDANCE WITH ALL APPLICABLE CODES.

CONNECTIONS:
ALL PIPING, FITTINGS, AND INTERCONNECTION SERVICES SHOWN ARE TO BE SUPPLIED AND INSTALLED BY LICENSED CONTRACTORS IN ACCORDANCE WITH ALL LOCAL CODES.

GAS CONNECTIONS:
EXTERNAL GAS REGULATORS, FLEXIBLE GAS LINES AND RESTRAINING CABLES PROVIDED WITH THE EQUIPMENT MUST BE INSTALLED BY LICENSED CONTRACTORS IN ACCORDANCE WITH ALL LOCAL CODES. INCOMING GAS MANIFOLD SUPPLY PRESSURE MUST NOT EXCEED 0.5 PSI (4" W.C.)

BY OTHERS:
VERIFY ALL EQUIPMENT LISTED AS BY OTHERS FOR SIZE AND MECHANICAL SERVICE REQUIREMENTS.

NOTE:
IN LINE WITH THE POLICY TO CONTINUALLY IMPROVE ITS PRODUCTS, THE MANUFACTURERS RESERVE THE RIGHT TO CHANGE MATERIALS AND SPECIFICATIONS WITHOUT NOTICE.

06-24-2022

●	CONNECTION POINT
○	COLD WATER
○	HOT WATER
○	HOT + COLD WATER
○	DRAIN
○	POWER
○	SWITCH
○	CORD SET
○	CONV. OUTLET RECP
○	DUPLEX RECP/TABLE
○	SINGLE RECP/TABLE
○	GAS
○	STEAM SUPPLY
○	STEAM RETURN
○	STEAM TAKE OFF
○	EXHAUST VENT
○	SUPPLY VENT
○	REFRIGERATION

PROJECT CODE
AUTH4

VULCAN
THE VULCAN HART COMPANY
BALTIMORE, MARYLAND
410-284-0660

AUTOGRAPH HOTEL
Austin

REVISIONS		By	Date	No.
	Revision	ddb		

NEXT STEP DESIGN
913 A West Street
Annapolis, MD 21401
410-263-1200

SCALE:
AS NOTED
DATE: 06/24/2022
DRAWN BY: DDB
AUTH4

1
OF 1