

Subject: RE: LEE HEALTH CARE - VL-LEEHC - Release # 3
 From: Sheila Oppeneer <sheila.openeer@vollrathco.com>
 Date: 7/9/2021, 11:02 AM
 To: David Bethel <ddb@davidbethel.com>, Jill Hundley <jhundley@vollrathco.com>

Hi David,
 Thanks for making the changes. Two comments on the PDF.
 Regarding the electrical, why does it state – TO BE DETERMINED?
 This was in the previous rev –

VOLTS	120	60	ELECTRICAL
0	1	1	NEMA 5-20
20.8 A			
Equipment	Voltage	LI Amp	
Hot/cold 1	120	10.4	
Hot/cold 2	120	10.4	
Total Amps		20.8	

Here are the electrical specifications from the spec sheet for the Hot/Cold unit.

SPECIFICATIONS

Item No.	Drain	Cutout Dimensions			Weight LB (Kg)	Voltage	Max Amp Draw	Comp. (HP)	Peak Heat of Rejection (BTUH)	Refrig. (Charge)	Watts Per Well	Plug
		Drop-in*	Control**	Louvers								
FC-6HC-02120	Manual											
FC-6HC-02120-AD	Auto	33 $\frac{1}{16}$ x 25 $\frac{1}{4}$	7 x 8 $\frac{1}{2}$	8 x 10	185	120	10.4	1/5	2800 Cold	R513A	625	NEMA 5-15P

If you have questions, please call me before Noon today or Monday.

Thanks,
 Sheila

From: David Bethel <ddb@davidbethel.com>
 Sent: Friday, July 9, 2021 7:02 AM
 To: Jill Hundley <jhundley@vollrathco.com>; Sheila Oppeneer <sheila.openeer@vollrathco.com>
 Subject: LEE HEALTH CARE - VL-LEEHC - Release # 3

07-09-2021 : 08:00:23a

--

DIRECT LINK : [HTTP://WWW.DAVIDBETHEL.COM/LEEHC/INDEX.HTM](http://www.davidbethel.com/leeHC/index.htm)

LEE HEALTH CARE - JILL HUNDLEY - LEEHC
 VL-LEEHC : LEE HEALTH CARE
 Created 07-08-2021 : 06:45:32.am

+++++

07-09-2021

Server 1 <-> Modify : Per Mark Up

Server 1 <-> Please Verify : Power Requirements

+++++

07-08-2021

Server 1 <-> Please Verify : 4" Legs

(2) BIB With Bypass Doors

Ventilation

Over Shelf Construction

+++++

Thanks! -David

David Bethel
 Fabricated Designs, Inc. v. 757-595-5949
<http://www.davidbethel.com> ddb@davidbethel.com

-Attachments:

VL-LEEHC_07.09.2021 edits.pdf

611 KB