



GAS CONNECTION #1
LOCATED IN ITEM: 27&32
PIPE SIZE: 1" NPT
CP HEIGHT: 30" AFF
TOTAL GAS LOAD: 562 MBTU
FEEDS: 30.1 29 28 31
NOTE: (2) Inlets

27	1 EA	VT12B	SPREADER	0 MBTU	1.0	30 AFF	CP IN BASE
28	1 EA	VCBB36S	CHARBROILER	149 MBTU	1.25	MANIFOLD	
29	1 EA	TGRD48	GRIDDLE	120 MBTU	1.25	MANIFOLD	
31	1 EA	V6B36S	RANGE	260 MBTU	1.25	MANIFOLD	
30.1	1 EA	36IRB	SALAMANDER	33 MBTU	0.75	INTERPLUMB	
32	1 EA	VT12B	SPREADER	0 MBTU	1.0	30 AFF	CP IN BASE

GENERAL NOTES - PLEASE READ

VENTILATION:
ALL COOKING EQUIPMENT MUST BE VENTILATED BY AN APPROVED APPLIANCE IN ACCORDANCE WITH ALL APPLICABLE CODES.

FIRE SUPPRESSION:
ALL COOKING EQUIPMENT MUST BE PROTECTED BY AN APPROVED FIRE SUPPRESSION SYSTEM IN ACCORDANCE WITH ALL APPLICABLE CODES.

CONNECTIONS:
ALL PIPING, FITTINGS, AND INTERCONNECTION SERVICES SHOWN ARE TO BE SUPPLIED AND INSTALLED BY LICENSED CONTRACTORS IN ACCORDANCE WITH ALL LOCAL CODES.

GAS CONNECTIONS:
EXTERNAL GAS REGULATORS, FLEXIBLE GAS LINES AND RESTRAINING CABLES PROVIDED WITH THE EQUIPMENT MUST BE INSTALLED BY LICENSED CONTRACTORS IN ACCORDANCE WITH ALL LOCAL CODES. INCOMING GAS MANIFOLD SUPPLY PRESSURE MUST NOT EXCEED 0.5 PSI (4" W.C.)

BY OTHERS:
VERIFY ALL EQUIPMENT LISTED AS BY OTHERS FOR SIZE AND MECHANICAL SERVICE REQUIREMENTS.

NOTE:
IN LINE WITH THE POLICY TO CONTINUALLY IMPROVE ITS PRODUCTS, THE MANUFACTURERS RESERVE THE RIGHT TO CHANGE MATERIALS AND SPECIFICATIONS WITHOUT NOTICE.

CP	CONNECTION POINT
CW	COLD WATER
HW	HOT WATER
HWC	HOT + COLD WATER
D	DRAIN
P	POWER
S	SWITCH
CS	CORD SET
CO	CONV OUTLET RECP
CD	DUPLEX RECP
CS	SINGLE RECP
G	GAS
SS	STEAM SUPPLY
CR	STEAM RETURN
ST	STEAM TAKE OFF
VE	EXHAUST VENT
VS	SUPPLY VENT
RF	REFRIGERATION

03-30-2020
03-02-2022 : 10:58:58a
03-02-2022 : 11:01:23a

PROJECT CODE
MMWIL

NEXT STEP DESIGN

**913 WEST ST.
ANNAPOLIS, MD 21401**

SCALE:
AS NOTED
DATE: 03-30-2020
DRAWN BY: DDB
VH-MMWIL

1
OF 1

VULCAN
THE VULCAN HART COMPANY
BALTIMORE, MARYLAND
410-284-0660

Marriott Moxy
Williamsburg, NY

No.	Date	By	Revision
02	03/20/2020	ddb	BLOCK OUT
04	03/02/2022		COMPLETE OVERHAUL